




Date : 2019-02-22

## CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
<b>TEST REPORT NUMBER</b> 'Assessment Reports' are not acceptable	20180959/MK23	<b>CERTIFICATE NUMBER</b>	SP 04/19
<b>DATE OF ISSUE</b>	2019/01/28	<b>DATE OF ISSUE</b>	2019/02/18
<b>DATE OF EXPIRY</b>	-	<b>DATE OF EXPIRY</b>	-
Manufacturer details			
<b>NAME OF FACTORY/ MANUFACTURER</b>	MOBIAK S.A.	<b>NAME OF THE BRAND</b>	MOBIAK S.A.
<b>FACTORY ADDRESS / REGION</b> (STREET / TOWN / CITY / COUNTRY)	AKROTIRI, CHANIA, CRETE, PC73100, GREECE	<b>MODEL / NO</b>	MBK18-030HFC-P1A
<b>WEBSITE</b>	<a href="https://www.mobiak.gr/">https://www.mobiak.gr/</a>	<b>LOGO ON THE PRODUCT</b>	
<b>TEL</b>	+30 28210 63222	<b>EMAIL</b>	<a href="mailto:info@mobiak.gr">info@mobiak.gr</a>



Product Details From Test Report		Reference Test Report page NO
<b>DESCRIPTION OF THE PRODUCT</b> (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Portable fire extinguisher with 3kg HFC236fa Fire rating 34B	1 - 2
<b>TEST STANDARD</b> (SUCH AS ASTM/BS EN/ DN ETC)	EN 3-7:2004+A1:2007 Portable fire extinguishers – Part 7 In conjunction with the requirements of EN 3-10:2009 Portable fire extinguishers – Part 10	1
<b>TEST DESCRIPTION</b>	1. Performance characteristics of the fire extinguisher 2. Conformity of submitted samples with all applicable clauses of EN3	2 - 3 5 - 6
<b>SPECIFICATION OF TEST SPECIMEN</b>	Fire extinguisher type: portable stored pressure type Nominal charge: 3kg HFC236fa Propellant: N <sub>2</sub> Provided quantity: 50 samples Date of receipt: 2018/06/13 & 2018/08/30	1 - 2 2
<b>TEST RESULT</b> (SUCH AS PASSED CRITERIA ___/ COMPLIED TO ___/ DURATION ___/ OBSERVATION ___/ ETC)	Performance characteristics of the fire extinguisher Class B fire rating achieved 34B pass Operating temperature range -10°C to +60°C pass Conformity of submitted samples with all applicable clauses of EN 3-7 pass	3 5 - 32
<b>PRODUCT APPLICATION GUIDELINE (END USE)</b> (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN ___/TO BE INSTALLED AT ___/TO BE CONNECTED WITH ___/TO BE INSTALLED WITH ___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN ___/NOT TO BE INSTALLED AT ___/ NOT TO BE INSTALLED WITH ___ ETC.	End use: Fire protection in the private, public and industrial sectors Operating instructions: Pull out safety pin Aim at the base of the fire Squeeze valve lever Avoid skin and eye contact In case of inhalation of the HFC236fa, seek medical help Suitable for use on live electrical equipment up to 1000V hold the nozzle at a minimum distance of 1m. Vessel under pressure: 15bar (20°C)	Annex 2



Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	MPA Dresden GmbH	NAME OF TEST FACILITY	MPA Dresden GmbH
CERTIFICATION BODY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Fuchsmühlenweg 6F D-09599 Freiberg Germany	TEST FACILITY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Fuchsmühlenweg 6F D-09599 Freiberg Germany
WEBSITE	<a href="http://www.mpa-dresden.de">http://www.mpa-dresden.de</a>	WEBSITE	<a href="http://www.mpa-dresden.de">http://www.mpa-dresden.de</a>
TEL	+ 49(0)3731 20 393-0	TEL	+ 49(0)3731 20 393-0
EMAIL	info@mpa-dresden.de	EMAIL	info@mpa-dresden.de
ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)</small>	DAkkS Deutsche Akkreditierungsstelle GmbH <a href="http://www.dakks.de">http://www.dakks.de</a>	ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)</small>	DAkkS Deutsche Akkreditierungsstelle GmbH <a href="http://www.dakks.de">http://www.dakks.de</a>
AS PER <small>(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)</small>	DIN EN ISO/IEC 17065	AS PER	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
VALIDITY	2023-08-19	VALIDITY	a) 2019-08-10 b) 2023-08-19
REFERENCE NUMBER:	D-ZE-17819-01-00	REFERENCE NUMBER:	a) D-PL-17819-01-00 b) D-IS-17819-01-00
CERTIFICATION MARK			

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	President & CEO of MOBIAK S.A. Manolis Svorakis	SIGNATURE	
EMAIL / TEL	<a href="mailto:info@mobiak.gr">info@mobiak.gr</a> +30 28210 63222	FACTORY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	Grad. Eng. Bernd Ruhle	SIGNATURE	
EMAIL / TEL	b.ruhle@mpa-dresden.de + 49(0)3731 20 393-0	CERTIFICATION BODY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

**ATTACHMENTS:**

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)