



Date :24.10.2018

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	201717778/AN 96	CERTIFICATE NUMBER	SP 09/18
DATE OF ISSUE	06.02.2018	DATE OF ISSUE	15.03.2018
DATE OF EXPIRY	Not applicable	DATE OF EXPIRY	Not Applicable
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	ANAF FIRE PROTECTION S.P.A.	NAME OF THE BRAND	ANAF
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	VIA DEL COMMERCIO, 4 27020 TORRE D'ISOLA (PV) ITALY	MODEL / NO	CS5-AB
WEBSITE	WWW.ANAF.EU	LOGO ON THE PRODUCT	ANAFGROUP
TEL	0039 (0)382 4533	EMAIL	info@anaf.eu



Product Details From Test Report		Reference Test Report page NO										
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Portable stored pressure fire extinguisher with 5 kg CO ₂ Fire Rating: 89 B	PAG. 2										
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 3-7:2004 + A1:2007 – Portable fire extinguisher – Part 7 EN3-10:2009 – Portable fire extinguisher – Part 10	PAG. 1										
TEST DESCRIPTION	EN3-7: The standard specifies the characteristics, performance requirement and test methods for portable fire extinguishers. EN3-10: Portable fire extinguishers. Provisions for evaluating the conformity of a portable fire extinguisher to EN 3-7											
SPECIFICATION OF TEST SPECIMEN	<table border="1"> <tr> <td>Fire extinguisher type:</td> <td>Portable stored pressure</td> </tr> <tr> <td>Nominal Charge:</td> <td>5 kg CO₂</td> </tr> <tr> <td>Propellant:</td> <td>N.A.</td> </tr> <tr> <td>Provided Quantity:</td> <td>1</td> </tr> <tr> <td>Date of receipt:</td> <td>2018-01-29</td> </tr> </table>	Fire extinguisher type:	Portable stored pressure	Nominal Charge:	5 kg CO ₂	Propellant:	N.A.	Provided Quantity:	1	Date of receipt:	2018-01-29	PAG.2
Fire extinguisher type:	Portable stored pressure											
Nominal Charge:	5 kg CO ₂											
Propellant:	N.A.											
Provided Quantity:	1											
Date of receipt:	2018-01-29											
TEST RESULT (SUCH AS PASSED CRITERIA ___/ COMPLIED TO ___/ DURATION ___/OBSERVATION ___/ETC)	<p>Performance characteristics of the fire extinguisher:</p> <table border="1"> <tr> <td>Class B Fire Rating achieved</td> <td>89 B</td> <td>PASSED</td> </tr> <tr> <td>Operating temperature range</td> <td>-30 °C +60 °C</td> <td>PASSED</td> </tr> <tr> <td>Conformity of the submitted samples with all applicable clause of EN3-7</td> <td></td> <td>PASSED</td> </tr> </table>	Class B Fire Rating achieved	89 B	PASSED	Operating temperature range	-30 °C +60 °C	PASSED	Conformity of the submitted samples with all applicable clause of EN3-7		PASSED	PAG. 2	
Class B Fire Rating achieved	89 B	PASSED										
Operating temperature range	-30 °C +60 °C	PASSED										
Conformity of the submitted samples with all applicable clause of EN3-7		PASSED										
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN ___/TO BE INSTALLED AT ___/TO BE CONNECTED WITH ___/TO BE INSTALLED WITH ___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN ___/NOT TO BE INSTALLED AT ___/ NOT TO BE INSTALLED WITH ___ ETC.	<p>End use: Fire protection in private, public and industrial sectors.</p> <p>Operating instructions: 1) Pull out safety pin 2) Press down release lever 3) Aim jet at base of fire</p> <p>Suitable for use on fire involving voltages of up to 1000 volts at not less than 1 meter distance. Do not expose to a heat source. Recharge after complete or partial use. Check extinguisher periodically for operational capacity. Use only approved spare parts when recharging or servicing.</p>	Anhang 2										

Laboratory and Certification body details



NAME OF CERTIFICATION BODY	MPA Dresden GmbH	NAME OF TEST FACILITY	MPA Dresden GmbH
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany	TEST FACILITY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany
WEBSITE	http://www.mpa-dresden.de	WEBSITE	http://www.mpa-dresden.de
TEL	+ 49(0)3731 20 393-0	TEL	+ 49(0)3731 20 393-0
EMAIL	info@mpa-dresden.de	EMAIL	info@mpa-dresden.de
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	DAkKS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de	ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	DAkKS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	DIN EN ISO/IEC 17065	AS PER (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	2023-08-19	VALIDITY (EXPIRY DATE OF LABORATORY ACCREDITATION)	a) 2019-08-10 b) 2023-08-19
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	D-ZE-17819-01-00	REFERENCE NUMBER: (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	a) D-PL-17819-01-00 b) D-IS-17819-01-00
CERTIFICATION MARK			



(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Yves ANAF	SIGNATURE	
EMAIL / TEL	info@anaf.eu 0039 (0)382 4533	FACTORY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	Bernd Ruhle	SIGNATURE	
EMAIL / TEL	b.ruhle@mpa-dresden.de +49 (0)3731 / 20393 - 151	CERTIFICATION BODY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)