**United Arab Emirates** Ministry of interior Civil Defense G.H.Q Fire intentional Lab & House Of Expertise & Training Center **Approval Committee** 



دولة الامارات العربية المتحدة وزارة الداخلية القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

Date: 2015-02-13



			Gmby	
	This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	2009-F-2264/EG 100	CERTIFICATE NUMBER	SP 106/10	
DATE OF ISSUE	2010-05-27	DATE OF ISSUE	2010-05-31	
DATE OF EXPIRY	_	DATE OF EXPIRY	_	
	Manufactur	er details		
NAME OF FACTORY/ MANUFACTURER	BAVARIA® EGYPT S.A.E.	NAME OF THE BRAND	BAVARIA®	
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	BAVARIA EGYPT S.A.E. Gisr El Suez St. Block 109-Industrial Zone, Ismailia Desert Road, 11511 Cairo, Egypt	MODEL / NO	Tornado EB 12	
WEBSITE	http://www.bavariafirefighting.com	LOGO ON THE PRODUCT	BAYAVRIVA	
TEL	Tel: +20 (2) 218 20 601 / 2 / 3 / 4 Fax: +20 (2) 218 20 609	EMAIL	info@bavaria-firefighting.com sales.uae@bavaria-firefighting.com, international.sales@bavaria.com.eg	

United Arab Emirates
Ministry of interior
Civil Defense G.H.Q
Fire intentional Lab & House
Of Expertise & Training Center
Approval Committee



دولة الامارات العربية المتحدة وزارة الداخلية القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

	Product Details From Test Report	Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Portable fire extinguisher with 12 kg ABC fire extinguishing powder Fire rating 55 A, 233 B, C	
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 3-7:2004+A1:2007 Portable fire extinguishers - Part 7 in conjunction with the requirements of EN 3-10:2009 Portable fire extinguishers - Part 10	1
TEST DESCRIPTION	<ol> <li>Performance characteristics of the fire extinguisher</li> <li>Conformity of submitted samples with all applicable clauses of EN 3</li> </ol>	2
SPECIFICATION OF TEST SPECIMEN	Fire extinguisher type: portable cartridge type  Nominal charge: 12 kg ABC powder  Propellant: 290 g CO <sub>2</sub> external gas cartridge  Provided quantity: 50 samples  Date of receipt: 2009-06-03	2
TEST RESULT  (SUCH AS PASSED CRITERIA/ COMPLIED TO/ DURATION/OBSERVATION/ETC)	Performance characteristics of the fire extinguisher Class A fire rating achieved 55 A pass Class B fire rating achieved 233 B pass Operating temperature range - 30 °C to 60 °C pass Conformity of submitted samples with all applicable clauses of EN 3-7 pass	2 4 - 37
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED INTO BE INSTALLED AT /TO BE CONNECTED WITH TO BE INSTALLED WITH ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN/NOT TO BE INSTALLED AT NOT TO BE INSTALLED WITHETC.	End use: Fire protection in the private, public and industrial sectors Operating instructions: Pull safety pin at turning valve Open turning valve of pressure bottle Squeeze pistol lever and attack fire from below Use only on fires of fire class A, B and C Caution in electric installations Up to 1000 V only. Minimum distance 1 m	2 Annex 2

**United Arab Emirates** Ministry of interior Civil Defense G.H.Q Fire intentional Lab & House Of Expertise & Training Center **Approval Committee** 



دولة الامارات العربية المتحدة وزارة الداخلية القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	MPA Dresden GmbH	NAME OF TEST FACILITY	MPA Dresden GmbH
CERTIFICATION BODY ADDRESS / REGION (STREET/TOWN/CITY/COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany	TEST FACILITY ADDRESS / REGION (STREET/TOWN/CITY/COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany
WEBSITE TEL	http://www.mpa-dresden.de + 49(0)3731 20 393-0	WEBSITE TEL	http://www.mpa-dresden.de + 49(0)3731 20 393-0
EMAIL	info@mpa-dresden.de	EMAIL	info@mpa-dresden.de
ACCREDITED BY  (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	DAkkS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de	ACCREDITED BY  (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	DAkkS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de
AS PER(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	DIN EN ISO/IEC 17065	AS PER	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
VALIDITY	2019-09-15	VALIDITY	a) 2019-08-10 b) 2018-09-12
REFERENCE NUMBER:	D-ZE-17819-01-00	REFERENCE NUMBER:	a) D-PL-17819-01-00 b) D-IS-17819-01-00
CERTIFICATION MARK	Drester		

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFAC- TURER'S SIGNATORY	Eng. Salah Zouzou Metry	SIGNATURE	Salar 2020
EMAIL / TEL	salah.zouzou@ bavaria.com.eg +20 2 21820 610 , +20 2 21820 611	FACTORY OFFICIAL SEAL	PAYARM PARAMETER

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICA- TION BODY SIGNATORY	Grad. Eng. Bernd Ruhle	SIGNATURE	Machine
EMAIL / TEL	b.ruhle@mpa-dresden.de + 49(0)3731 20 393-0	CERTIFICATION BODY OFFICIAL SEAL	MPA Dresden Gribh

**ATTACHMENTS:** 

COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)