United Arab Emirates Ministry of interior Civil Defense G.H.Q Fire intentional Lab & House Of Expertise & Training Center **Approval Committee**



المتحــــدة العربيــــة الامــــارات دولــة الداخليــــة وزارة المدني للدفاع العامــة القيــــادة العالميــــة المختـــبرات اعتمـــاد لجنــة التــدريب ومعاهــد الخــبرةوبيـوت

Date: 2017-06-20

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following				
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	2007-F-3313/DA16	CERTIFICATE NUMBER	SP16/08	
DATE OF ISSUE	2008-01-23	DATE OF ISSUE	2010-04-01	
DATE OF EXPIRY		DATE OF EXPIRY		
No Burstin	Manufacti	urer details		
NAME OF FACTORY/ MANUFACTURER	POWER SAINTS LTD.	NAME OF THE BRAND	FIRE BABY	
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Tianhua Industrial District, Langxia Street Scene, Yuyao City, Zhejiang, China	MODEL / NO	PSMWZ9	
WEBSITE	http://powersaints.en.alibaba.com/	LOGO ON THE PRODUCT	FIREBABY	
TEL	+86 (0)574-62181918	EMAIL	jose@powersaints.com linda@saintsea.com	

United Arab Emirates Ministry of interior Civil Defense G.H.Q Fire intentional Lab & House Of Expertise & Training Center **Approval Committee**



المتحـــدة العربيـــة الامـــارات دولــة الداخليـــة وزارة المــدني للــدفاع العامــة القيـــادة العالميـــة المختــبرات اعتمــاد لجنـة التــدريب ومعاهــد الخــبرةوبيــوت

	Product Details From Test Report	Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Portable fire extinguisher With 9L water fire extinguisher Fire rating 21A	1,2
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN3-7:2004-01+A1:2007 in conjunction with the requirement EN3-10:2009	ts of 1
TEST DESCRIPTION	 Performance characteristics of Fire extinguisher Conformity of submitted samples with all applicable clau EN3 	ses of 4
SPECIFICATION OF TEST SPECIMEN	Fire extinguisher type: portable stored pressure type Nominal charge: 9L water Propellant: N2 Provided quantity: 20 Date of submission: 2007-09-11	2
TEST RESULT (SUCH AS PASSED CRITERIA_/ COMPLIED TO_/ DURATION/OBSERVATION/ETC)	Performance characteristics of the fire extinguisher Class A fire rating achieved 21A PASS Operating temperature range 5°C to 60°C PASS Conformity of submitted samples with all applicable clauses of EN3-7 PASS	
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN/TO BE INSTALLED AT/TO BE CONNECTED WITH/TO BE INSTALLED WITH ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN/NOT TO BE INSTALLED AT/ NOT TO BE INSTALLED WITH ETC.	End use: Fire protection in the private, public and industrial sectors Operating instructions: Pull out safety pin Direct the nozzle to the seat of fire Squeeze the operating lever Use only on fires of fire class A Caution in electric installations UP to 1000V only, Minimum distance 1 m	2 Annex2

United Arab Emirates Ministry of interior Civil Defense G.H.Q Fire intentional Lab & House Of Expertise & Training Center **Approval Committee**



المتحـــدة العربيـــة الامـــارات دولــة الداخليـــة وزارة المــدني للـــدفاع العامــة القيــــادة العالميـــة المختـــبرات اعتمــاد لجنــة التــدريب ومعاهــد الخــبرةوبيــوت

NAME OF CERTIFICATION BODY	MPA Dresden GmbH	NAME OF TEST FACILITY	MPA Dresden GmbH
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany	TEST FACILITY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany
WEBSITE	http://www.mpa-dresden.de	WEBSITE	http://www.mpa-dresden.de
TEL	+ 49(0)3731 20 393-0	TEL	+ 49(0)3731 20 393-0
EMAIL	info@mpa-dresden.de	EMAIL	info@mpa-dresden.de
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFI- CATION BODY, ALONG WITH WEBSITE)	DAkkS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de	ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	DAkkS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de
AS PER(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	DIN EN ISO/IEC 17065	AS PER	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
VALIDITY	2019-09-15	VALIDITY	a) 2019-08-10 b) 2018-09-12
REFERENCE NUMBER:	D-ZE-17819-01-00	REFERENCE NUMBER:	a) D-PL-17819-01-00 b) D-IS-17819-01-00

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFAC- TURER'S SIGNATORY	GONG BIAO	SIGNATURE	Gang Piece
EMAIL / TEL	gm@powersaints.com 0086-0571-86811600	FACTORY OFFICIAL SEAL	SA INSTANT

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICA- TION BODY SIGNATORY	Grad. Eng. Bernd Ruhle	SIGNATURE	Kulia
EMAIL / TEL	b.ruhle@mpa-dresden.de + 49(0)3731 20 393-0	CERTIFICATION BODY OFFICIAL SEAL	accurate Poresden Griding

ATTACHMENTS:

• COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)