



Date :24.10.2018

CERTIFICATE OF COMPLIANCE


This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	a)2013-F-1843/AN 68 b)20161117 / AN 87	CERTIFICATE NUMBER	SP 175/13
DATE OF ISSUE	a) b) 08.11.2016	DATE OF ISSUE	05.09.2018
DATE OF EXPIRY	Not applicable	DATE OF EXPIRY	Not Applicable
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	ANAF FIRE PROTECTION S.P.A.	NAME OF THE BRAND	ANAF
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	VIA DEL COMMERCIO, 4 27020 TORRE D'ISOLA (PV) ITALY	MODEL / NO	FS9-J
WEBSITE	WWW.ANAF.EU	LOGO ON THE PRODUCT	ANAFGROUP
TEL	0039 (0)382 4533	EMAIL	info@anaf.eu



Product Details From Test Report		Reference Test Report page NO												
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Portable stored pressure fire extinguisher with 9 l water with additive Fire Rating: 34A 233B	PAG. 2												
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 3-7:2004 + A1:2007 – Portable fire extinguisher – Part 7 EN3-10:2009 – Portable fire extinguisher – Part 10	PAG. 1												
TEST DESCRIPTION	EN3-7: The standard specifies the characteristics, performance requirement and test methods for portable fire extinguishers. EN3-10: Portable fire extinguishers. Provisions for evaluating the conformity of a portable fire extinguisher to EN 3-7													
SPECIFICATION OF TEST SPECIMEN	<table border="1"> <tr> <td>Fire extinguisher type:</td> <td>Portable stored pressure</td> </tr> <tr> <td>Nominal Charge:</td> <td>9 l water + additives</td> </tr> <tr> <td>Propellant:</td> <td>Nitrogen</td> </tr> <tr> <td>Provided Quantity:</td> <td>N. A.</td> </tr> <tr> <td>Date of receipt:</td> <td>N. A.</td> </tr> </table>	Fire extinguisher type:	Portable stored pressure	Nominal Charge:	9 l water + additives	Propellant:	Nitrogen	Provided Quantity:	N. A.	Date of receipt:	N. A.	PAG.2		
Fire extinguisher type:	Portable stored pressure													
Nominal Charge:	9 l water + additives													
Propellant:	Nitrogen													
Provided Quantity:	N. A.													
Date of receipt:	N. A.													
TEST RESULT (SUCH AS PASSED CRITERIA ___/ COMPLIED TO ___/ DURATION ___/ OBSERVATION ___/ ETC)	<p>Performance characteristics of the fire extinguisher:</p> <table border="1"> <tr> <td>Class A Fire Rating achieved</td> <td>34 A</td> <td>PASSED</td> </tr> <tr> <td>Class B Fire Rating achieved</td> <td>233 B</td> <td>PASSED</td> </tr> <tr> <td>Operating temperature range</td> <td>0 °C +60 °C</td> <td>PASSED</td> </tr> <tr> <td>Conformity of the submitted samples with all applicable clause of EN3-7</td> <td></td> <td>PASSED</td> </tr> </table>	Class A Fire Rating achieved	34 A	PASSED	Class B Fire Rating achieved	233 B	PASSED	Operating temperature range	0 °C +60 °C	PASSED	Conformity of the submitted samples with all applicable clause of EN3-7		PASSED	PAG. 2
Class A Fire Rating achieved	34 A	PASSED												
Class B Fire Rating achieved	233 B	PASSED												
Operating temperature range	0 °C +60 °C	PASSED												
Conformity of the submitted samples with all applicable clause of EN3-7		PASSED												
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN ___/ TO BE INSTALLED AT ___/ TO BE CONNECTED WITH ___/ TO BE INSTALLED WITH ___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN ___/ NOT TO BE INSTALLED AT ___/ NOT TO BE INSTALLED WITH ___ ETC.	<p>End use: Fire protection in private, public and industrial sectors.</p> <ol style="list-style-type: none"> 1) Hold upright, withdraw safety clip; 2) Squeeze lever to operate, release to interrupt; 3) Aim Jet at base of fire. <p>Suitable for use on fire involving voltages of up to 1000 volts at not less than 1 meter distance. Recharge after complete or partial use. Check extinguisher periodically for operational capacity. Use only approved spare parts when recharging or servicing.</p>	Anhang 2												



Laboratory and Certification body details

NAME OF CERTIFICATION BODY	MPA Dresden GmbH	NAME OF TEST FACILITY	MPA Dresden GmbH
CERTIFICATION BODY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Fuchsmühlenweg 6F D-09599 Freiberg Germany	TEST FACILITY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Fuchsmühlenweg 6F D-09599 Freiberg Germany
WEBSITE	http://www.mpa-dresden.de	WEBSITE	http://www.mpa-dresden.de
TEL	+ 49(0)3731 20 393-0	TEL	+ 49(0)3731 20 393-0
EMAIL	info@mpa-dresden.de	EMAIL	info@mpa-dresden.de
ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)</small>	DAkks Deutsche Akkreditierungsstelle GmbH http://www.dakks.de	ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)</small>	DAkks Deutsche Akkreditierungsstelle GmbH http://www.dakks.de
AS PER <small>(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)</small>	DIN EN ISO/IEC 17065	AS PER <small>(STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)</small>	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
VALIDITY <small>(EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)</small>	2023-08-19	VALIDITY <small>(EXPIRY DATE OF LABORATORY ACCREDITATION)</small>	a) 2019-08-10 b) 2023-08-19
REFERENCE NUMBER: <small>(CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small>	D-ZE-17819-01-00	REFERENCE NUMBER: <small>(THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small>	a) D-PL-17819-01-00 b) D-IS-17819-01-00
CERTIFICATION MARK			

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER

NAME OF MANUFACTURER'S SIGNATORY	Yves ANAF	SIGNATURE	
EMAIL / TEL	info@anaf.eu 0039 (0)382 4533	FACTORY OFFICIAL SEAL	ANAF FIRE PROTECTION S.p.A. VIA DEL COMMERCIO, 4 27020 TORRE D'ISOLA (PV) P.IVA 02610340180
NOTES: I Undertake that all data and information provided are genuine and accurate			



(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	Bernd Ruhle	SIGNATURE	
EMAIL / TEL	b.ruhle@mpa-dresden.de +49 (0)3731 / 20393 - 151	CERTIFICATION BODY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)