United Arab Emirates
Ministry of interior
Civil Defense G.H.Q
Fire intentional Lab & House
Of Expertise & Training Center
Approval Committee



المتحـــدة العربيـــة الامـــار ات دولــة الداخليـــة وزارة المـــدني للـــدفاع العامــة القيــــادة العالميــــة المختـــبرات اعتمـــاد لجنــة التـــدريب ومعاهــد الخـــبرةوبيــوت

Date: 2017-06-20

## **CERTIFICATE OF COMPLIANCE**

	This certificate of complia	nce validate	s the following				
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	20151417/SSG61	CERTIFICATE NUMBER	SP 250/15				
DATE OF ISSUE	2016-02-25	DATE OF ISSUE	2016-03-07				
DATE OF EXPIRY		DATE OF EXPIRY					
	Manufacturer details						
NAME OF FACTORY/ MANUFACTURER	POWER SAINTS LTD.	NAME OF THE BRAND	FIRE BABY				
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Tianhua Industrial District, Langxia Street Scene, Yuyao City, Zhejiang, China	MODEL / NO	PSMPZ6A/5				
WEBSITE	http://powersaints.en.alibaba.com/	LOGO ON THE PRODUCT	FIREBABY				
TEL	+86 (0)574-62181918	EMAIL	jose@powersaints.com linda@saintsea.com				

United Arab Emirates
Ministry of interior
Civil Defense G.H.Q
Fire intentional Lab & House
Of Expertise & Training Center
Approval Committee



المتحدة العربية الامارات دولة الداخلية وزارة المدني للدفاع العامة القيادة العالمية المختبرات اعتماد لجنة التدريب ومعاهد الخبرةوبيوت

	Product Details From Test Report	Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/SENSITIVITY ETC)	Portable fire extinguisher With 6kg ABC30 powder fire extinguisher Fire rating 43A 233B	1,2
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN3-7:2004-01+A1:2007 in conjunction with the requirements of EN3-10:2009	1
TEST DESCRIPTION	<ol> <li>Performance characteristics of Fire extinguisher</li> <li>Conformity of submitted samples with all applicable clauses of EN3</li> </ol>	2
SPECIFICATION OF TEST SPECIMEN	Fire extinguisher type: portable stored pressure type Nominal charge: 6KG ABC powder Propellant: N2 Provided quantity: 20 Date of submission: 2015-10-22	2
TEST RESULT  (SUCH AS PASSED CRITERIA_/ COMPLIED TO_/ DURATION_/OBSERVATION_/ETC)	Performance characteristics of the fire extinguisher Class A fire rating achieved 43A 233B Operating temperature range -30°C to 60°C PASS Conformity of submitted samples with all applicable clauses of EN3-7 PASS	2 4-35
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED INTO BE INSTALLED ATTO BE CONNECTED WITHTO BE INSTALLED WITHETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED INNOT TO BE INSTALLED AT NOT TO BE INSTALLED WITHETC.	End use: Fire protection in the private, public and industrial sectors Operating instructions: Pull out safety pin Direct the nozzle to the seat of fire Squeeze the operating lever Use only on fires of fire class B Caution in electric installations UP to 1000V only, Minimum distance 1 m	2 Annex2

United Arab Emirates Ministry of interior Civil Defense G.H.Q Fire intentional Lab & House Of Expertise & Training Center **Approval Committee** 



المتحـــدة العربيـــة الامـــارات دولــة الداخليـــة وزارة المــدني للـــدفاع العامــة القيـــادة العالميــــة المختــبرات اعتمــاد لجنــة التــدريب ومعاهــد الخــبرةوبيــوت

NAME OF CERTIFICATION BODY	MPA Dresden GmbH	NAME OF TEST FACILITY	MPA Dresden GmbH
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany	TEST FACILITY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany
WEBSITE	http://www.mpa-dresden.de	WEBSITE	http://www.mpa-dresden.de
TEL	+ 49(0)3731 20 393-0	TEL	+ 49(0)3731 20 393-0
EMAIL	info@mpa-dresden.de	EMAIL	info@mpa-dresden.de
ACCREDITED BY  (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	DAkkS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de	ACCREDITED BY  (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	DAkkS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de
AS PER(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	DIN EN ISO/IEC 17065	AS PER	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
VALIDITY	2019-09-15	VALIDITY	a) 2019-08-10 b) 2018-09-12
REFERENCE NUMBER:	D-ZE-17819-01-00	REFERENCE NUMBER:	a) D-PL-17819-01-00 b) D-IS-17819-01-00

	(ENDORSEMENT) TO BE S	SIGNED BY MANUFACTU	IRER
NAME OF MANUFAC- TURER'S SIGNATORY	GONG BIAO	SIGNATURE	Graning Brav
EMAIL / TEL	gm@powersaints.com 0086-0571-86811600	FACTORY OFFICIAL SEAL	TO ONE

Eng. Bernd Ruhle	SIGNATURE	1/10
		The same
e@mpa-dresden.de )3731 20 393-0	CERTIFICATION BODY OFFICIAL SEAL	d accurate
)	3731 20 393-0	BODY OFFICIAL

## **ATTACHMENTS:**

• COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)