

ATTESTATION OF CONFORMITY (CERTIFICATE OF COMPLIANCE)

2019-Z-0553

This is to confirm that the below stated composite material is tested in accordance with ASTM E84 by an EN ISO/IEC 17025:2005 accredited testing laboratory.


The conformity to ASTM E84 is confirmed.

The requirements of the standards are fulfilled.

Issued to:	Serge Ferrari S.A.S. Zone Industrielle BP 54 F 38352 La Tour du Pin Cedex France
Product Type / Model:	Composite material for textile architecture - Facades 371
Manufacturer:	Serge Ferrari S.A.S. Zone Industrielle BP 54 F 38352 La Tour du Pin Cedex; France
Requirements:	ASTM E84-18a
Test report Reference number	103736609SAT-005
Validity	2024-05-02, extension is possible
Attestation comprises:	1 page, 1 annex

The examination has been carried out on test samples of the product, submitted by the manufacturer. The attestation does not include an assessment of the manufacturing plant.

2019-05-03


Grad. Eng. B. Ruhle
Manager of the certification office



The publications of the Attestation of conformity, also in the form of extracts and references to tests or certification for advertising, need in every case the written agreement of the MPA Dresden GmbH. Every page of this certificate is stamped with the seal of the MPA Dresden GmbH.

Specification of the product

PRODUCT	Mesh polyester yarns coated with PVC flame retardant on both sides and varnished	
TRADE NAME	371	
APPLICATION	For textile architecture	
YARN	Polyester 1100 dtex, 45% PVC flame retardant 55%	
WEIGHT	440 g/m ² ± 5%	
THICKNESS	0.71 mm ± 10%	
NATURE OF FLAME RETARDANT ADDITIVES	aluminium trioxide, antimony trioxide included in the formulation of PVC	
SURFACE BURNING CHARACTERISTICS	Flame spread index	5
	Smoke developed Index	195
	Classification	Class A

