



Date : 2017-05-29

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	20151077/OG22	CERTIFICATE NUMBER	SP183/15
DATE OF ISSUE	18.09.2015	DATE OF ISSUE	25.09.2015
DATE OF EXPIRY	N/A	DATE OF EXPIRY	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	KZWM OGNIOPHON S.A.	NAME OF THE BRAND	KZWM OGNIOPHON S.A.
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	ul. Krakowska 83c , 34-120 Andrychów, POLAND	MODEL / NO	GP-4x ABC/MP
WEBSITE	www.ogniochron.eu	LOGO ON THE PRODUCT	
TEL	+48 33 875 10 70	EMAIL	biuro@ogniochron.eu



Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	4 kg ABC dry chemical powder potable fire extinguisher fire rating 27A and 144B, operating temperature range -30°C to +60°C.	1 / 37; 2 / 37
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 3-7 : 2004-01 + A1 : 2007 Portable fire extinguishers – Part 7 in conjunction with the requirements of EN 3-10:2009 Portable fire extinguishers – Part 10	1 / 37
TEST DESCRIPTION	1. Performance characteristics of the fire extinguisher	2 / 37
	2. Conformity of submitted samples with all applicable clauses EN 3	4 / 37
SPECIFICATION OF TEST SPECIMEN	Fire extinguisher type: portable stored pressure type Nominal charge: 4kg ABC powder Propellant: N ₂ Provided quantity: 50 samples Date of receipt: 2015-06-02	1 / 37 2 / 37
TEST RESULT (SUCH AS PASSED CRITERIA ___/ COMPLIED TO ___/ DURATION ___/OBSERVATION ___/ETC)	Performance characteristics of the fire extinguisher Class A fire rating 27A pass	2 / 37
	Class B fire rating 144B pass Operating temperature range -30°C to +60°C pass Conformity of submitted samples with all applicable clauses of EN 3-7 pass	4 / 37
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN ___/TO BE INSTALLED AT ___/TO BE CONNECTED WITH ___/TO BE INSTALLED WITH ___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN ___/NOT TO BE INSTALLED AT ___/ NOT TO BE INSTALLED WITH ___ ETC.	End use: Fire protection in the private, public and industrial sectors. Operating instructions: Pull out safety pin Direct the nozzle to the seat of fire Squeeze the operating lever Use only on fires of fire class A, B and C Caution in electric installations Up to 1000V only. Minimum distance 1m.	2 / 37 Annex 2



Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	MPA Dresden GmbH	NAME OF TEST FACILITY	MPA Dresden GmbH
CERTIFICATION BODY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Fuchsmühlenweg 6F D-09599 Freiberg Germany	TEST FACILITY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Fuchsmühlenweg 6F D-09599 Freiberg Germany
WEBSITE	http://www.mpa-dresden.de	WEBSITE	http://www.mpa-dresden.de
TEL	+ 49(0)3731 20 393-0	TEL	+ 49(0)3731 20 393-0
EMAIL	info@mpa-dresden.de	EMAIL	info@mpa-dresden.de
ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)</small>	DAkKS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de	ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)</small>	DAkKS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de
AS PER <small>(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)</small>	DIN EN ISO/IEC 17065	AS PER	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
VALIDITY	2019-09-15	VALIDITY	a) 2019-08-10 b) 2018-09-12
REFERENCE NUMBER:	D-ZE-17819-01-00	REFERENCE NUMBER:	a) D-PL-17819-01-00 b) D-IS-17819-01-00
CERTIFICATION MARK			

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Grzegorz Tomiak President	SIGNATURE	 mgr Grzegorz Tomiak Prezes Zarządu
EMAIL / TEL	biuro@ogniochron.eu +48 33 875 10 70	FACTORY OFFICIAL SEAL	 ZWM OGNIOCHRON — Spółka Akcyjna — Krzyszowska 83c Tel. (33) 875-10-70 17 Andrychów Fax (33) 875-10-77 43-20-5 1431 REGON 070909888 041 7084681
NOTES: I Undertake that all data and information provided are genuine and accurate			

29

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	Grad. Eng. Bernd Ruhle	SIGNATURE	
EMAIL / TEL	b.ruhle@mpa-dresden.de + 49(0)3731 20 393-0	CERTIFICATION BODY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)