



Date :08.05.2018

## CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
<b>TEST REPORT NUMBER</b> 'Assessment Reports' are not acceptable	a)03-6-124/AN 08 b)2008-F-1930/AN 29 c)2009-F-0320/AN 38 d)2013-F-4539/AN 71 e)20150795/AN 82	<b>CERTIFICATE NUMBER</b>	SP 37/03
<b>DATE OF ISSUE</b>	a) 22.01.2004 b) 02.07.2008 c) d)28.11.2018 e) 04.08.2015	<b>DATE OF ISSUE</b>	01.07.2014
<b>DATE OF EXPIRY</b>	Not applicable	<b>DATE OF EXPIRY</b>	Not applicable
Manufacturer details			
<b>NAME OF FACTORY / MANUFACTURER</b>	ANAF FIRE PROTECTION S.P.A.	<b>NAME OF THE BRAND</b>	ANAF
<b>FACTORY ADDRESS / REGION</b> (STREET / TOWN / CITY / COUNTRY)	VIA DEL COMMERCIO, 4 27020 TORRE D'ISOLA (PV) ITALY	<b>MODEL / NO</b>	PS2-Y ABC
<b>WEBSITE</b>	<a href="http://WWW.ANAF.EU">WWW.ANAF.EU</a>	<b>LOGO ON THE PRODUCT</b>	ANAFGROUP
<b>TEL</b>	0039 (0)382 4533	<b>EMAIL</b>	info@anaf.eu







Product Details From Test Report		Reference Test Report page NO												
<b>DESCRIPTION OF THE PRODUCT</b> (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Portable stored pressure fire extinguisher with 2 kg ABC powder Fire Rating: 13A 89B C	PAG. 2												
<b>TEST STANDARD</b> (SUCH AS ASTM/BS EN/ DN ETC)	EN 3-7:2004 + A1:2007 – Portable fire extinguisher – Part 7 EN3-10:2009 – Portable fire extinguisher – Part 10	PAG.1 PAG.2												
<b>TEST DESCRIPTION</b>	<b>EN3-7:</b> The standard specifies the characteristics, performance requirement and test methods for portable fire extinguishers. <b>EN3-10:</b> Portable fire extinguishers. Provisions for evaluating the conformity of a portable fire extinguisher to EN 3-7	PAG.2												
<b>SPECIFICATION OF TEST SPECIMEN</b>	<table border="1"> <tr> <td>Fire extinguisher type:</td> <td>Portable stored pressure</td> </tr> <tr> <td>Nominal Charge:</td> <td>2 kg ABC powder</td> </tr> <tr> <td>Propellant:</td> <td>Nitrogen</td> </tr> <tr> <td>Provided Quantity:</td> <td>N. A.</td> </tr> <tr> <td>Date of receipt:</td> <td>N. A.</td> </tr> </table>	Fire extinguisher type:	Portable stored pressure	Nominal Charge:	2 kg ABC powder	Propellant:	Nitrogen	Provided Quantity:	N. A.	Date of receipt:	N. A.	PAG. 2		
Fire extinguisher type:	Portable stored pressure													
Nominal Charge:	2 kg ABC powder													
Propellant:	Nitrogen													
Provided Quantity:	N. A.													
Date of receipt:	N. A.													
<b>TEST RESULT</b> (SUCH AS PASSED CRITERIA ___/ COMPLIED TO ___/ DURATION ___/ OBSERVATION ___/ ETC)	<p>Performance characteristics of the fire extinguisher:</p> <table border="1"> <tr> <td>Class A Fire Rating achieved</td> <td>13 A</td> <td>PASSED</td> </tr> <tr> <td>Class B Fire Rating achieved</td> <td>89 B</td> <td>PASSED</td> </tr> <tr> <td>Operating temperature range</td> <td>-30 °C +60 °C</td> <td>PASSED</td> </tr> <tr> <td>Conformity of the submitted samples with all applicable clause of EN3-7</td> <td></td> <td>PASSED</td> </tr> </table>	Class A Fire Rating achieved	13 A	PASSED	Class B Fire Rating achieved	89 B	PASSED	Operating temperature range	-30 °C +60 °C	PASSED	Conformity of the submitted samples with all applicable clause of EN3-7		PASSED	PAG. 2
Class A Fire Rating achieved	13 A	PASSED												
Class B Fire Rating achieved	89 B	PASSED												
Operating temperature range	-30 °C +60 °C	PASSED												
Conformity of the submitted samples with all applicable clause of EN3-7		PASSED												
<b>PRODUCT APPLICATION GUIDELINE (END USE)</b> (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN ___/TO BE INSTALLED AT ___/TO BE CONNECTED WITH ___/TO BE INSTALLED WITH ___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN ___/NOT TO BE INSTALLED AT ___/ NOT TO BE INSTALLED WITH ___ ETC.	<ol style="list-style-type: none"> <li>1) Hold upright, withdraw safety clip;</li> <li>2) Aim Jet at base of fire and squeeze lever to operate.</li> </ol> <p>Suitable for use on fire involving voltages of up to 1000 volts at not less than 1 meter distance. Recharge after complete or partial use. Check extinguisher periodically for operational capacity. Use only approved spare parts when recharging or servicing.</p>	Anhang 2												







### Laboratory and Certification body details

<b>NAME OF CERTIFICATION BODY</b>	MPA Dresden GmbH	<b>NAME OF TEST FACILITY</b>	MPA Dresden GmbH
<b>CERTIFICATION BODY ADDRESS / REGION</b> (STREET / TOWN / CITY / COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany	<b>TEST FACILITY ADDRESS / REGION</b> (STREET / TOWN / CITY / COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany
<b>WEBSITE</b>	<a href="http://www.mpa-dresden.de">http://www.mpa-dresden.de</a>	<b>WEBSITE</b>	<a href="http://www.mpa-dresden.de">http://www.mpa-dresden.de</a>
<b>TEL</b>	+ 49(0)3731 20 393-0	<b>TEL</b>	+ 49(0)3731 20 393-0
<b>EMAIL</b>	info@mpa-dresden.de	<b>EMAIL</b>	info@mpa-dresden.de
<b>ACCREDITED BY</b> (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	DAkKS Deutsche Akkreditierungsstelle GmbH <a href="http://www.dakks.de">http://www.dakks.de</a>	<b>ACCREDITED BY</b> (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	DAkKS Deutsche Akkreditierungsstelle GmbH <a href="http://www.dakks.de">http://www.dakks.de</a>
<b>AS PER</b> (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	DIN EN ISO/IEC 17065	<b>AS PER</b> (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
<b>VALIDITY</b> (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	2023-08-19	<b>VALIDITY</b> (EXPIRY DATE OF LABORATORY ACCREDITATION)	a) 2019-08-10 b) 2023-08-19
<b>REFERENCE NUMBER:</b> (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	D-ZE-17819-01-00	<b>REFERENCE NUMBER:</b> (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	a) D-PL-17819-01-00 b) D-IS-17819-01-00
<b>CERTIFICATION MARK</b>	 		

### (ENDORSEMENT) TO BE SIGNED BY MANUFACTURER

<b>NAME OF MANUFACTURER'S SIGNATORY</b>	Yves ANAF	<b>SIGNATURE</b>	
<b>EMAIL / TEL</b>	info@anaf.eu 0039 (0)382 4533	<b>FACTORY OFFICIAL SEAL</b>	 ANAF FIRE PROTECTION S.p.A. VIA DEL COMMERCIO, 4 27020 TORRE D'ISOLA (PV) P.IVA 02610340180
<b>NOTES:</b> I Undertake that all data and information provided are genuine and accurate			



(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	Bernd Ruhle	SIGNATURE	
EMAIL / TEL	<a href="mailto:b.ruhle@mpa-dresden.de">b.ruhle@mpa-dresden.de</a> +49 (0)3731 / 20393 - 151	CERTIFICATION BODY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

**ATTACHMENTS:**

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)