




Date : 2015-02-13

## CERTIFICATE OF COMPLIANCE

Belegexemplar  
MPA Dresden GmbH


<b>This certificate of compliance validates the following</b>			
<b>TEST REPORT NUMBER</b> <small>'Assessment Reports' are not acceptable</small>	a) 06-06-2323/B 182 b) 2009-F-0637/B 228	<b>CERTIFICATE NUMBER</b>	SP 75/11
<b>DATE OF ISSUE</b>	a) 2006-07-25 b) 2009-04-09	<b>DATE OF ISSUE</b>	2011-06-01
<b>DATE OF EXPIRY</b>	—	<b>DATE OF EXPIRY</b>	—
<b>Manufacturer details</b>			
<b>NAME OF FACTORY/ MANUFACTURER</b>	BAVARIA® EGYPT S.A.E.	<b>NAME OF THE BRAND</b>	BAVARIA®
<b>FACTORY ADDRESS / REGION</b> <small>(STREET / TOWN / CITY / COUNTRY)</small>	BAVARIA EGYPT S.A.E. Gisir El Suez St. Block 109-Industrial Zone, Ismailia Desert Road, 11511 Cairo, Egypt	<b>MODEL / NO</b>	Sigma 2
<b>WEBSITE</b>	<a href="http://www.bavariafirefighting.com">http://www.bavariafirefighting.com</a>	<b>LOGO ON THE PRODUCT</b>	
<b>TEL</b>	Tel: +20 (2) 218 20 601 / 2 / 3 / 4 Fax: +20 (2) 218 20 609	<b>EMAIL</b>	info@bavaria-firefighting.com sales.uae@bavaria-firefighting.com, international.sales@bavaria.com.eg



Product Details From Test Report		Reference Test Report page NO
<b>DESCRIPTION OF THE PRODUCT</b> (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Portable fire extinguisher with 2 kg CO <sub>2</sub> as extinguishing medium Fire rating 34 B	1, 2
<b>TEST STANDARD</b> (SUCH AS ASTM/BS EN/ DN ETC)	EN 3-7:2004+A1:2007 Portable fire extinguishers - Part 7 in conjunction with the requirements of EN 3-10:2009 Portable fire extinguishers - Part 10	1
<b>TEST DESCRIPTION</b>	1. Performance characteristics of the fire extinguisher	2
	2. Conformity of submitted samples with all applicable clauses of EN 3	4
<b>SPECIFICATION OF TEST SPECIMEN</b>	Fire extinguisher type: portable stored pressure type	1
	Nominal charge: 2 kg CO <sub>2</sub>	
	Propellant: -	
	Provided quantity: 50 samples	2
	Date of receipt: 2009-02-13	
<b>TEST RESULT</b> (SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)	Performance characteristics of the fire extinguisher	2
	Class B fire rating achieved 34 B pass	
	Operating temperature range - 30 °C to 60 °C pass	
	Conformity of submitted samples with all applicable clauses of EN 3-7 pass	4 - 37
<b>PRODUCT APPLICATION GUIDELINE (END USE)</b> (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT___/TO BE CONNECTED WITH___/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ ETC.	End use: Fire protection in the private, public and industrial sectors	2
	Operating instructions: Pull out safety strip Direct the horn to the seat of fire Press down valve lever Use only on fires of fire class B Caution in electric installations Up to 1000 V only. Minimum distance 1 m	Annex 2



### Laboratory and Certification body details

NAME OF CERTIFICATION BODY	MPA Dresden GmbH	NAME OF TEST FACILITY	MPA Dresden GmbH
CERTIFICATION BODY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Fuchsmühlenweg 6F D-09599 Freiberg Germany	TEST FACILITY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Fuchsmühlenweg 6F D-09599 Freiberg Germany
WEBSITE	<a href="http://www.mpa-dresden.de">http://www.mpa-dresden.de</a>	WEBSITE	<a href="http://www.mpa-dresden.de">http://www.mpa-dresden.de</a>
TEL	+ 49(0)3731 20 393-0	TEL	+ 49(0)3731 20 393-0
EMAIL	info@mpa-dresden.de	EMAIL	info@mpa-dresden.de
ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)</small>	DAkKS Deutsche Akkreditierungsstelle GmbH <a href="http://www.dakks.de">http://www.dakks.de</a>	ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)</small>	DAkKS Deutsche Akkreditierungsstelle GmbH <a href="http://www.dakks.de">http://www.dakks.de</a>
AS PER <small>(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)</small>	DIN EN ISO/IEC 17065	AS PER	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
VALIDITY	2019-09-15	VALIDITY	a) 2019-08-10 b) 2018-09-12
REFERENCE NUMBER:	D-ZE-17819-01-00	REFERENCE NUMBER:	a) D-PL-17819-01-00 b) D-IS-17819-01-00
CERTIFICATION MARK			

### (ENDORSEMENT) TO BE SIGNED BY MANUFACTURER

NAME OF MANUFACTURER'S SIGNATORY	Eng. Salah Zouzou Metry	SIGNATURE	
EMAIL / TEL	salah.zouzou@bavaria.com.eg +20 2 21820 610 , +20 2 21820 611	FACTORY OFFICIAL SEAL	

NOTES: I Undertake that all data and information provided are genuine and accurate

### (ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY

NAME OF CERTIFICATION BODY SIGNATORY	Grad. Eng. Bernd Ruhle	SIGNATURE	
EMAIL / TEL	b.ruhle@mpa-dresden.de + 49(0)3731 20 393-0	CERTIFICATION BODY OFFICIAL SEAL	

NOTES: I Undertake that all data and information provided are genuine and accurate

#### ATTACHMENTS:

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)